

Pressure Vessel Inspection Code: In-service Inspection, Rating, Repair, and Alteration

API 510
ELEVENTH EDITION, OCTOBER 2022



American
Petroleum
Institute

Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed. The use of API publications is voluntary. In some cases, third parties or authorities having jurisdiction may choose to incorporate API standards by reference and may mandate compliance.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to ensure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be used. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

Users of this standard should not rely exclusively on the information contained in this document. Sound business, scientific, engineering, and safety judgment should be used in employing the information contained herein.

Work sites and equipment operations may differ. Users are solely responsible for assessing their specific equipment and premises in determining the appropriateness of applying the standard. At all times users should employ sound business, scientific, engineering, and judgment safety when using this standard.

API is not undertaking to meet the duties of employers, manufacturers, or suppliers to warn and properly train and equip their employees, and others exposed, concerning health and safety risks and precautions, nor undertaking their obligations to comply with authorities having jurisdiction.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001-5571.

Foreword

This edition of API 510 supersedes all previous editions of API 510. Each edition, revision, or addendum to this API code may be used beginning with the date of issuance shown on the cover page for that edition, revision, or addendum. This API code becomes effective six months after the date of issuance for equipment that is rerated, reconstructed, relocated, repaired, modified (altered), inspected, and tested per this code unless an impact assessment is completed and documented. The owner-operator, or otherwise any entity designated as a “user”, is responsible for assessing the impact of any changes in this API code relative to their current inspection and mechanical integrity program in order to determine the level of compliance, identify any gaps, and develop an appropriate schedule for compliance and/or document exceptions or alternative approaches, as appropriate. The impact assessment and its documentation should be completed within three months after the date of issuance of this edition. The completion of the appropriate schedule for compliance from the impact assessment should not exceed twelve months from the date of issuance of this edition.

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

The verbal forms used to express the provisions in this document are as follows.

Shall: As used in a standard, “shall” denotes a minimum requirement in order to conform to the standard.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required in order to conform to the standard.

May: As used in a standard, “may” denotes a course of action permissible within the limits of a standard.

Can: As used in a standard, “can” denotes a statement of possibility or capability.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001.

Suggested revisions are invited and should be submitted to the Standards Department, API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001, standards@api.org.

Contents

	Page
1	Scope..... 1
1.1	General Application..... 1
1.2	Specific Applications 2
2	Normative References 3
3	Terms, Definitions, Acronyms, and Abbreviations 4
3.1	Terms and Definitions 4
3.2	Acronyms and Abbreviations 13
4	Owner-operator Inspections Organization 14
4.1	Owner-operator Organization Responsibilities 14
4.2	Engineer 16
4.3	Repair Organization 16
4.4	Inspector 17
4.5	Examiners 17
4.6	Other Personnel..... 17
4.7	Inspection Organization Audits 18
5	Inspection, Examination, and Pressure-testing Practices..... 18
5.1	Inspection Plans 18
5.2	Risk-based Inspection (RBI) 20
5.3	Preparation for Inspection..... 21
5.4	Inspection for Different Types of Damage Mechanisms and Failure Modes..... 22
5.5	Types of Inspection and Surveillance for Pressure Vessels 24
5.6	Condition-monitoring Locations (CMLs) 29
5.7	Condition-monitoring Methods..... 30
5.8	Pressure Testing 32
5.9	Material Verification and Traceability 34
5.10	Inspection of In-service Welds..... 35
5.11	Inspection and Repair of Flanged Joints 35
5.12	Inspection of Shell and Tube Heat Exchangers..... 36
6	Interval/Frequency and Extent of Inspection 36
6.1	General..... 36
6.2	Inspection During Installation and Service Changes 36
6.3	RBI..... 37
6.4	External Inspection 37
6.5	Internal, On-stream, and Thickness Measurement Inspections..... 37
6.6	Pressure-relieving Devices 39
6.7	Deferral of Inspections, Tests, and Examinations 41
6.8	Deferral of Inspection Repair Recommendation Due Dates 42
6.9	Review of Inspection Repair Recommendations 42
7	Inspection Data Evaluation, Analysis, and Recording 42
7.1	Corrosion Rate Determination 42
7.2	Remaining Life Calculations 44
7.3	Maximum Allowable Working Pressure (MAWP) Determination..... 44
7.4	Analysis of Corroded Regions 45
7.5	FFS Evaluations 46
7.6	Required Thickness Determination..... 47

Contents

	Page
7.7	Evaluation of Existing Equipment with Minimal Documentation 47
7.8	Reports and Records 48
8	Repairs, Alterations, and Rerating of Pressure Vessels and Pressure-relieving Devices 49
8.1	Repairs and Alterations 49
8.2	Temporary Repairs 50
8.3	Permanent Repair 52
8.4	Welding and Hot Tapping 54
8.5	PWHT 54
8.6	Preheat or Controlled-deposition Welding (CDW) Methods as Alternatives to PWHT 55
8.7	NDE of Welds 58
8.8	Weld Inspection for Vessels Subject to Brittle Fracture 58
8.9	Rerating 58
9	Alternative Rules for Exploration and Production (E&P) Pressure Vessels 61
9.1	Scope and Specific Exemptions 61
9.2	Inspection Program 61
9.3	Pressure Test 65
9.4	Safety Relief Devices 65
9.5	Records 66
	Annex A (normative) Code Exemptions 67
	Annex B (normative) Inspector Certification 69
	Annex C (informative) Sample Pressure Vessel Inspection Record 71
	Annex D (informative) Sample Repair, Alteration, or Rerating of Pressure Vessel Form 72
	Annex E (informative) Technical Inquiries 74
	Bibliography 75

Figures

1	Rerating Vessels Using the Latest Edition or Addendum of the ASME <i>BPVC</i> Allowable Stresses 60
2	Sample Additional Nameplate 61

Tables

1	Values of Spherical Radius Factor K_1 46
2	Change in Design Margin with Construction Code 48
3	Qualification Limits for Base Metal and Weld Deposit Thicknesses for the CDW Method (Notch Toughness Testing Required) 57

Pressure Vessel Inspection Code: In-service Inspection, Rating, Repair, and Alteration

1 Scope

1.1 General Application

1.1.1 Coverage

This inspection code covers the in-service inspection, repair, alteration, and rerating activities for pressure vessels and the pressure-relieving devices (PRDs) protecting these vessels. This inspection code applies to all hydrocarbon and chemical process vessels that have been placed in service unless specifically excluded per [1.2.2](#); however, it could also be applied to process vessels in other industries at owner-operator discretion. This includes:

- a) vessels constructed in accordance with an applicable construction code [e.g., ASME *Boiler and Pressure Vessel Code (BPVC)*]; where a pressure vessel has been constructed to the American Society of Mechanical Engineers (ASME) *Section VIII Code*, API 510 is intended to apply to Divisions 1 and 2 and not Division 3;
- b) vessels constructed without a construction code (noncode vessels);
- c) vessels constructed and approved as jurisdictional-special based upon jurisdiction acceptance of particular design, fabrication, inspection, testing, and installation;
- d) nonstandard vessels.

However, vessels that have been officially decommissioned (i.e. no longer are an asset of record from a financial/accounting standpoint) are no longer covered by this “in-service inspection” code. Abandoned-in-place vessels may still need some amount of inspection and/or risk mitigation to assure they do not become a hazard because of continuing deterioration. Pressure vessels temporarily out of service and preserved for potential future use are still covered by this code.

The ASME *BPVC* and other recognized construction codes are written for new construction; however, most of the technical requirements for design, welding, nondestructive examination (NDE), and materials can be applied to the inspection, rerating, repair, and alteration of in-service pressure vessels. If for some reason an item that has been placed in service cannot follow the construction code because of its new construction orientation, the requirements for design, material, fabrication, and inspection shall conform to API 510 rather than to the construction code. If in-service vessels are covered by requirements in the construction code and API 510 or if there is a conflict between the two codes, the requirements of API 510 shall take precedence. As an example of the intent of API 510, the phrase “applicable requirements of the construction code” has been used in API 510 instead of the phrase “in accordance with the construction code.”

1.1.2 Intent

The application of this inspection code is restricted to owner-operators that employ or have access to the following technically qualified individuals and organizations:

- a) an authorized inspection agency;
- b) a repair organization;
- c) an engineer;
- d) an inspector;