

CODE CASES

2023

ASME Boiler and
Pressure Vessel Code
An International Code

Boilers and
Pressure Vessels

Markings such as “ASME,” “ASME Standard,” or any other marking including “ASME,” ASME logos, or the ASME Single Certification Mark shall not be used on any item that is not constructed in accordance with all of the applicable requirements of the Code or Standard. Use of the ASME Single Certification Mark requires formal ASME certification; if no certification program is available, such ASME markings may not be used. (For Certification and Accreditation Programs, see <https://www.asme.org/certification-accreditation>.)

Items produced by parties not formally possessing an ASME Certificate may not be described, either explicitly or implicitly, as ASME certified or approved in any code forms or other document.

AN INTERNATIONAL CODE

2023 ASME Boiler & Pressure Vessel Code

2023 Edition

July 1, 2023

CODE CASES

Boilers and Pressure Vessels



The American Society of
Mechanical Engineers

Two Park Avenue • New York, NY • 10016 USA

Date of Issuance: July 1, 2023

This international code or standard was developed under procedures accredited as meeting the criteria for American National Standards and it is an American National Standard. The standards committee that approved the code or standard was balanced to ensure that individuals from competent and concerned interests had an opportunity to participate. The proposed code or standard was made available for public review and comment, which provided an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not “approve,” “certify,” “rate,” or “endorse” any item, construction, proprietary device, or activity. ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor does ASME assume any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representatives or persons affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

The endnotes and preamble in this document (if any) are part of this American National Standard.



ASME Collective Membership Mark



ASME Single Certification Mark

“ASME” and the above ASME symbols are registered trademarks of The American Society of Mechanical Engineers.

No part of this document may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Library of Congress Catalog Card Number: 56-3934

Adopted by the Council of The American Society of Mechanical Engineers, 1914; latest edition 2023.

The American Society of Mechanical Engineers
Two Park Avenue, New York, NY 10016-5990

Copyright © 2023 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All rights reserved
Printed in U.S.A.

TABLE OF CONTENTS

List of Sections	iv
Correspondence With the Committee	v
Summary of Changes	vii
Cross-Referencing in the ASME BPVC	ix
Notes to Numeric Index	x
Numeric Index	xi
Subject Index	xxi
Index of Material Specifications Referred to in Cases	xxxii

(23)

LIST OF SECTIONS

SECTIONS

- I Rules for Construction of Power Boilers

- II Materials
 - Part A — Ferrous Material Specifications
 - Part B — Nonferrous Material Specifications
 - Part C — Specifications for Welding Rods, Electrodes, and Filler Metals
 - Part D — Properties (Customary)
 - Part D — Properties (Metric)

- III Rules for Construction of Nuclear Facility Components
 - Subsection NCA — General Requirements for Division 1 and Division 2
 - Appendices
 - Division 1
 - Subsection NB — Class 1 Components
 - Subsection NCD — Class 2 and Class 3 Components
 - Subsection NE — Class MC Components
 - Subsection NF — Supports
 - Subsection NG — Core Support Structures
 - Division 2 — Code for Concrete Containments
 - Division 3 — Containment Systems for Transportation and Storage of Spent Nuclear Fuel and High-Level Radioactive Material
 - Division 4 — Fusion Energy Devices
 - Division 5 — High Temperature Reactors

- IV Rules for Construction of Heating Boilers

- V Nondestructive Examination

- VI Recommended Rules for the Care and Operation of Heating Boilers

- VII Recommended Guidelines for the Care of Power Boilers

- VIII Rules for Construction of Pressure Vessels
 - Division 1
 - Division 2 — Alternative Rules
 - Division 3 — Alternative Rules for Construction of High Pressure Vessels

- IX Welding, Brazing, and Fusing Qualifications

- X Fiber-Reinforced Plastic Pressure Vessels

- XI Rules for Inservice Inspection of Nuclear Reactor Facility Components
 - Division 1 — Rules for Inspection and Testing of Components of Light-Water-Cooled Plants
 - Division 2 — Requirements for Reliability and Integrity Management (RIM) Programs for Nuclear Reactor Facilities

- XII Rules for Construction and Continued Service of Transport Tanks

- XIII Rules for Overpressure Protection

CORRESPONDENCE WITH THE COMMITTEE

(23)

General

ASME codes and standards are developed and maintained by committees with the intent to represent the consensus of concerned interests. Users of ASME codes and standards may correspond with the committees to propose revisions or cases, report errata, or request interpretations. Correspondence for this Section of the ASME Boiler and Pressure Vessel Code (BPVC) should be sent to the staff secretary noted on the Section's committee web page, accessible at <https://go.asme.org/CSCcommittees>.

NOTE: See ASME BPVC Section II, Part D for guidelines on requesting approval of new materials. See Section II, Part C for guidelines on requesting approval of new welding and brazing materials ("consumables").

Revisions and Errata

The committee processes revisions to this Code on a continuous basis to incorporate changes that appear necessary or desirable as demonstrated by the experience gained from the application of the Code. Approved revisions will be published in the next edition of the Code.

In addition, the committee may post errata and Special Notices at <http://go.asme.org/BPVCerrata>. Errata and Special Notices become effective on the date posted. Users can register on the committee web page to receive e-mail notifications of posted errata and Special Notices.

This Code is always open for comment, and the committee welcomes proposals for revisions. Such proposals should be as specific as possible, citing the paragraph number(s), the proposed wording, and a detailed description of the reasons for the proposal, including any pertinent background information and supporting documentation.

Cases

- (a) The most common applications for cases are
 - (1) to permit early implementation of a revision based on an urgent need
 - (2) to provide alternative requirements
 - (3) to allow users to gain experience with alternative or potential additional requirements prior to incorporation directly into the Code
 - (4) to permit use of a new material or process
- (b) Users are cautioned that not all jurisdictions or owners automatically accept cases. Cases are not to be considered as approving, recommending, certifying, or endorsing any proprietary or specific design, or as limiting in any way the freedom of manufacturers, constructors, or owners to choose any method of design or any form of construction that conforms to the Code.
- (c) The committee will consider proposed cases concerning the following topics only:
 - (1) equipment to be marked with the ASME Single Certification Mark, or
 - (2) equipment to be constructed as a repair/replacement activity under the requirements of Section XI
- (d) A proposed case shall be written as a question and reply in the same format as existing cases. The proposal shall also include the following information:
 - (1) a statement of need and background information
 - (2) the urgency of the case (e.g., the case concerns a project that is underway or imminent)
 - (3) the Code Section and the paragraph, figure, or table number(s) to which the proposed case applies
 - (4) the edition(s) of the Code to which the proposed case applies
- (e) A case is effective for use when the public review process has been completed and it is approved by the cognizant supervisory board. Cases that have been approved will appear in the next edition or supplement of the Code Cases books, "Boilers and Pressure Vessels" or "Nuclear Components." Each Code Cases book is updated with seven Supplements. Supplements will be sent or made available automatically to the purchasers of the Code Cases books until the next edition of the Code. Annulments of Code Cases become effective six months after the first announcement of the

annulment in a Code Case Supplement or Edition of the appropriate Code Case book. The status of any case is available at <http://go.asme.org/BPVCCDatabase>. An index of the complete list of Boiler and Pressure Vessel Code Cases and Nuclear Code Cases is available at <http://go.asme.org/BPVCC>.

Interpretations

(a) Interpretations clarify existing Code requirements and are written as a question and reply. Interpretations do not introduce new requirements. If a revision to resolve conflicting or incorrect wording is required to support the interpretation, the committee will issue an intent interpretation in parallel with a revision to the Code.

(b) Upon request, the committee will render an interpretation of any requirement of the Code. An interpretation can be rendered only in response to a request submitted through the online Interpretation Submittal Form at <http://go.asme.org/InterpretationRequest>. Upon submitting the form, the inquirer will receive an automatic e-mail confirming receipt.

(c) ASME does not act as a consultant for specific engineering problems or for the general application or understanding of the Code requirements. If, based on the information submitted, it is the opinion of the committee that the inquirer should seek assistance, the request will be returned with the recommendation that such assistance be obtained. Inquirers may track the status of their requests at <http://go.asme.org/Interpretations>.

(d) ASME procedures provide for reconsideration of any interpretation when or if additional information that might affect an interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME committee or subcommittee. ASME does not “approve,” “certify,” “rate,” or “endorse” any item, construction, proprietary device, or activity.

(e) Interpretations are published in the ASME Interpretations Database at <http://go.asme.org/Interpretations> as they are issued.

Committee Meetings

The ASME BPVC committees regularly hold meetings that are open to the public. Persons wishing to attend any meeting should contact the secretary of the applicable committee. Information on future committee meetings can be found at <http://go.asme.org/BCW>.

SUMMARY OF CHANGES

The 2023 Edition of the Code Cases includes Code Case actions published through Supplement 7 to the 2021 Edition.

Changes listed below are identified on the pages by a margin note, **(23)**, placed next to the affected area. Errata, if any, are identified by a margin note, **(E)**, placed next to the affected area.

<i>Page</i>	<i>Location</i>	<i>Change</i>
iv	List of Sections	(1) Under Section III, Division 4 added (2) Title of Section XI and subtitle of Section XI, Division 2 revised (3) Information on interpretations and Code cases moved to “Correspondence With the Committee”
v	Correspondence With the Committee	Added
ix	Cross-Referencing in the ASME BPVC	Updated
x	Notes to Numeric Index	Updated
xi	Numeric Index	Updated
xxi	Subject Index	Updated
xxxii	Index of Material Specifications Referred to in Cases	Updated
1 (2179-11)	2179-11	Revised
1 (2203-2)	2203-2	Revised
1 (2256)	2256	Annulled
1 (2403)	2403	Impending annulment
1 (2540-1)	2540-1	Revised
1 (2546)	2546	Annulled
1 (2570)	2570	Annulled
1 (2571-1)	2571-1	Impending annulment
1 (2586-1)	2586-1	Impending annulment
1 (2591-1)	2591-1	Revised and impending annulment
1 (2633)	2633	Impending annulment
1 (2656)	2656	Annulled
1 (2657)	2657	Annulled
1 (2710-1)	2710-1	Annulled
1 (2763-2)	2763-2	Revised
1 (2764-1)	2764-1	Annulled
1 (2765-1)	2765-1	Revised
1 (2768)	2768	Impending annulment

<i>Page</i>	<i>Location</i>	<i>Change</i>
1 (2769-1)	2769-1	Annulled
1 (2788)	2788	Impending annulment
1 (2801-1)	2801-1	Revised
1 (2802-1)	2802-1	Revised
1 (2850)	2850	Impending annulment
1 (2858)	2858	Annulled
1 (2885)	2885	Annulled
1 (2923)	2923	Impending annulment
1 (2962)	2962	Impending annulment
1 (3005)	3005	Impending annulment
1 (3013)	3013	Annulled
1 (3015)	3015	Annulled
1 (3061)	3061	Added
1 (3062)	3062	Added
1 (3063)	3063	Added
1 (3064)	3064	Added
1 (3065)	3065	Added
1 (3066)	3066	Added
1 (3067)	3067	Added
1 (3068)	3068	Added
1 (3069)	3069	Added
1 (3070)	3070	Added

CROSS-REFERENCING IN THE ASME BPVC

(23)

Paragraphs within the ASME BPVC may include subparagraph breakdowns, i.e., nested lists. The following is a guide to the designation and cross-referencing of subparagraph breakdowns:

(a) Hierarchy of Subparagraph Breakdowns

- (1) First-level breakdowns are designated as (a), (b), (c), etc.
- (2) Second-level breakdowns are designated as (1), (2), (3), etc.
- (3) Third-level breakdowns are designated as (-a), (-b), (-c), etc.
- (4) Fourth-level breakdowns are designated as (-1), (-2), (-3), etc.
- (5) Fifth-level breakdowns are designated as (+a), (+b), (+c), etc.
- (6) Sixth-level breakdowns are designated as (+1), (+2), etc.

(b) Cross-References to Subparagraph Breakdowns. Cross-references within an alphanumerically designated paragraph (e.g., PG-1, UIG-56.1, NCD-3223) do not include the alphanumerical designator of that paragraph. The cross-references to subparagraph breakdowns follow the hierarchy of the designators under which the breakdown appears. The following examples show the format:

- (1) If X.1(c)(1)(-a) is referenced in X.1(c)(1), it will be referenced as (-a).
- (2) If X.1(c)(1)(-a) is referenced in X.1(c)(2), it will be referenced as (1)(-a).
- (3) If X.1(c)(1)(-a) is referenced in X.1(e)(1), it will be referenced as (c)(1)(-a).
- (4) If X.1(c)(1)(-a) is referenced in X.2(c)(2), it will be referenced as X.1(c)(1)(-a).

NOTES TO NUMERIC INDEX

- All Code Cases remain available for use until annulled by the ASME Boiler and Pressure Vessel Standards Committees. Code Cases will be reviewed routinely for possible incorporation into the body of the ASME Boiler and Pressure Vessel Code.
- Supplement 7 is the last supplement published for the 2021 edition. Supplement 8 is incorporated into the 2023 edition.
- Cases may be used beginning with the date of approval shown on the Case.
- Annulled Cases will remain in the Numeric Index and Subject Index until the next Edition, at which time they will be deleted.
- Newly revised cases supersede previous versions. Previous code case number will be added in the "Annulled Date/Supersedes" column next to the newly revised code case.
- The digit following a Case Number is used to indicate the number of times a Case has been revised.
- The Cases are arranged in numerical order, and each page of a Case is identified at the top with the appropriate Case Number.

Legend of Abbreviations

Supp. = Supplement

R = Reinstated

NUMERIC INDEX

(23)

Case	Approval Date	Errata	Impending Annulment Date	Annulled Date/ Supersedes
1325-18	6-23-2005
1750-31	9-30-2021
1827-3	12-30-2006
1849-1	8-4-2004
1855-2	12-18-2018
1876-5	4-26-2013
1924-2	12-30-2006
1932-5	8-4-2006
1934	5-25-1983
1935-4	9-23-2007
1936-3	2-20-2002
1949-4	2-20-2004
1968-1	12-2-1990
1993-7	10-26-2016
2016-1	8-12-1996
2038-5	2-7-2000
2055-2	5-4-1999
2063-6	10-2-2008
2073-1	10-29-1999
2093	6-19-1990
2120-1	10-29-1999
2127-3	9-18-2006
2142-6	8-1-2018
2143-2	4-1-2014
2146	11-25-1992
2150	8-12-1993
2151-3	9-30-2018
2172	8-8-1994
2179-11	11-4-2022	2179-10
2180-8	8-8-2022
2192-10	12-10-2020
2195-1	2-7-2000
2196-5	4-2-2020
2197-1	2-17-2000
2199-9	4-6-2022
2203-2	12-7-2022	2203-1
2205	6-5-1995
2217-5	6-17-2003
2222-2	10-29-1999
2223-3	6-20-2002
2224-2	9-18-2006
2226-2	5-21-2003
2230-2	10-29-1999
2239-1	10-29-1999
2244-2	1-20-2000
2247	7-9-1998
2249	8-11-1997
2254-1	4-2-2020
2256	8-11-1997	6-21-2023
2260-3	12-2-2019
2276-1	2-17-2000
2286-6	10-30-2015
2297	11-30-1999
2300	9-23-1999

Case	Approval Date	Errata	Impending Annulment Date	Annulled Date/ Supersedes
2304-2	5-12-2004
2305-1	12-14-2009
2318	9-23-1999
2321-1	2-20-2002
2324-1	3-21-2012
2327-3	8-8-2022
2334	7-10-2000
2346-1	2-14-2003
2350	2-26-2001
2351-1	R11-30-2017
2353-1	10-18-2004
2357-2	12-30-2006
2359-2	6-23-2005
2377	1-27-2003
2385-1	5-4-2004
2397-2	8-30-2022
2400	2-14-2003
2402-1	9-25-2012
2403	2-13-2003	...	10-1-2025	...
2407	2-13-2003
2411	6-23-2005
2416	2-13-2003
2418-2	6-23-2014
2419	5-21-2003
2421	5-21-2003
2426	1-27-2003
2427	5-21-2003
2428-4	4-17-2020
2430	1-12-2005
2432-1	6-20-2008
2439	2-14-2003
2440	2-20-2004
2445-2	6-25-2010
2446	11-29-2004
2458-3	1-22-2007
2461-2	9-12-2017
2463-1	9-8-2010
2468-3	3-13-2020
2469-1	10-21-2009
2473-2	12-18-2018
2475	11-29-2004
2478-1	R3-13-2019
2481-1	11-17-2016
2489	2-22-2005
2493-1	9-12-2017
2494-2	3-28-2017
2496-4	9-30-2018
2498	6-20-2008
2500	11-2-2004
2511	8-3-2005
2512	10-27-2005
2514-1	7-7-2006
2516	8-3-2005
2518-2	12-8-2014
2520	8-4-2006
2523-2	8-30-2018
2527	4-26-2007
2529	10-27-2005
2537	10-27-2005
2538	1-19-2006
2540-1	11-4-2022	2540

Case	Approval Date	Errata	Impending Annulment Date	Annulled Date/ Supersedes
2544-2	1-26-2009
2546	1-19-2006	12-30-2022
2554	1-3-2006
2556-2	9-15-2009
2563	12-30-2006
2565	12-30-2006
2568-1	12-21-2016
2570	4-2-2007	6-21-2023
2571-1	1-26-2009
2576	12-30-2006
2577	10-2-2008
2581	4-26-2007
2585-1	9-15-2009
2586-1	10-2-2008	...	1-1-2024	...
2587	8-6-2007
2588	10-19-2007
2591-1	12-7-2022	...	1-1-2024	2591
2594-2	9-30-2018
2595	1-4-2008
2596-1	4-6-2011
2597	5-21-2008
2598	1-29-2008
2603-2	4-15-2017
2604	10-2-2008
2605-4	7-24-2019
2606	1-26-2009
2607	1-26-2009
2608	1-26-2009
2609	1-26-2009
2610	1-26-2009
2611	1-26-2009
2613	1-30-2009
2616-1	9-23-2013
2617	5-9-2009
2618	7-5-2009
2619	6-24-2009
2620-3	10-6-2019
2624-1	12-2-2019
2627	9-30-2009
2628	9-30-2009
2629	1-13-2010
2630	1-13-2010
2631	12-14-2009
2632	10-21-2009
2633	12-14-2009	...	1-1-2024	...
2634	12-14-2009
2636	1-13-2010
2639	1-20-2010
2640-1	1-20-2011
2641	12-14-2009
2643-1	10-6-2019
2645	3-10-2010
2649	7-2-2010
2652-1	6-23-2014
2653-1	3-5-2018
2655	9-8-2010
2656	8-24-2010	12-30-2022
2657	7-28-2010	12-30-2022
2658	9-8-2010
2659	9-8-2010
2660	9-8-2010

Case	Approval Date	Errata	Impending Annulment Date	Annulled Date/ Supersedes
2661-2	4-23-2019
2663	12-7-2010
2665-1	7-13-2011
2666	1-12-2011
2668-1	1-31-2017
2671-2	12-18-2018
2672	6-16-2011
2673	6-16-2011
2674-1	9-30-2018
2675-1	8-30-2022
2676	6-16-2011
2677	4-6-2011
2678-1	9-26-2011
2679	6-16-2011
2680	6-16-2011
2681-1	9-30-2018
2682	7-13-2011
2683	7-13-2011
2684-5	8-1-2018
2686	8-5-2011
2687-1	12-18-2017
2688	8-19-2011
2690-1	10-2-2014
2691	8-23-2011
2692	8-19-2011
2693-1	4-4-2012
2694	9-26-2011
2696	7-13-2011
2697-1	8-1-2016
2698-2	4-2-2020
2701-1	1-10-2013
2702-7	4-6-2022
2703-1	8-1-2018
2704	9-26-2011
2705	8-9-2011
2706	11-7-2011
2707	11-7-2011
2708	11-7-2011
2710-1	1-7-2013	6-21-2023
2711-1	9-30-2018
2712-2	1-24-2022
2715	2-13-2012
2717	3-21-2012
2718	3-21-2012
2719	4-4-2012
2720	4-4-2012
2721	4-4-2012
2722-1	10-25-2012
2723	4-4-2012
2724	4-4-2012
2725-1	10-6-2020
2726	5-24-2012
2727-1	9-30-2018
2728-1	9-30-2018
2729-2	4-3-2019
2730	6-28-2012
2731	5-16-2012
2733-3	8-1-2018
2734-3	8-1-2018
2735	9-25-2012
2736-2	6-23-2014

Case	Approval Date	Errata	Impending Annulment Date	Annulled Date/ Supersedes
2737-2	9-30-2018
2738	9-25-2012
2739	9-25-2012
2740-1	9-30-2018
2741	8-15-2012
2742	8-29-2012
2743	8-29-2012
2744	8-29-2012
2745-1	7-29-2014
2746	8-29-2012
2747	8-29-2012
2748-2	9-30-2018
2749-2	9-30-2018
2750	12-12-2012
2751	12-12-2012
2752-1	5-30-2019
2753-1	3-13-2019
2754	12-12-2012
2755	12-18-2012
2756	1-7-2013
2757-2	7-15-2021
2758	1-10-2013
2759	1-10-2013
2760-1	12-12-2019
2761-1	11-7-2017
2763-2	11-29-2022	2763-1
2764-1	9-2-2014	12-30-2022
2765-1	11-29-2022	2765
2767	6-18-2013
2768	8-6-2013	...	1-1-2024	...
2769-1	12-18-2017	12-30-2022
2770-1	11-2-2021
2771	6-18-2013
2772	6-18-2013
2773	8-27-2013
2774	9-18-2013
2775	9-18-2013
2776	9-18-2013
2777-1	9-30-2018
2778	9-18-2013
2779	9-18-2013
2780-1	6-1-2015
2781-2	8-27-2019
2782	10-23-2013
2783	9-28-2013
2784	11-1-2013
2786	11-1-2013
2787-1	1-31-2022
2788	11-1-2013	...	1-1-2024	...
2789-1	9-19-2022
2790	11-1-2013
2791	1-6-2014
2792	1-23-2014
2793	3-18-2014
2794	3-18-2014
2795	3-18-2014
2797	3-18-2014
2798	4-1-2014
2799-1	6-26-2018
2801-1	11-29-2022	2801
2802-1	11-29-2022	2802

Case	Approval Date	Errata	Impending Annulment Date	Annulled Date/ Supersedes
2803	5-19-2014
2804	6-23-2014
2805	5-14-2014
2806	6-23-2014
2807-1	12-30-2018
2808-1	4-29-2022
2809	10-2-2014
2810	10-2-2014
2811	11-14-2014
2812	12-31-2014
2813	1-12-2015
2814	1-8-2015
2815-1	9-30-2018
2816	1-8-2015
2817	1-8-2015
2820	11-29-2014
2821	2-24-2015
2822-2	12-11-2017
2823-1	12-18-2017
2824	3-23-2015
2825	3-6-2015
2826-1	8-14-2018
2827-2	6-29-2018
2830	6-1-2015
2831-1	9-30-2018
2832	7-21-2015
2833	7-15-2015
2834	7-15-2015
2835	9-15-2015
2836-4	1-6-2022
2837	9-15-2015
2838	9-15-2015
2839-2	5-4-2022
2840-1	9-30-2018
2841	2-17-2016
2843-2	12-11-2017
2844	12-9-2015
2847-1	12-12-2019
2848	1-20-2016
2849	1-20-2016
2850	2-23-2016	...	1-1-2024	...
2851	2-9-2016
2852	3-17-2016
2853	3-30-2015
2857	5-2-2016
2858	6-17-2016	3-30-2023
2859	6-17-2016
2860	9-1-2016
2861	9-1-2016
2864-3	8-8-2022
2865	9-30-2016
2866	9-30-2016
2867-3	12-7-2020
2868-1	3-20-2018
2869	11-28-2016
2870-1	3-21-2017
2871-1	3-21-2017
2872	11-30-2016
2873	11-30-2016
2874	11-30-2016
2875	11-30-2016

Case	Approval Date	Errata	Impending Annulment Date	Annulled Date/Supersedes
2876-1	3-21-2017
2877	12-12-2016
2878	12-22-2016
2879	1-10-2017
2880	3-21-2017
2881	3-8-2017
2882-1	7-14-2018
2883	4-12-2017
2884	4-4-2017
2885	6-16-2017	12-30-2022
2886	8-7-2017
2887-1	12-12-2017
2888	8-24-2017
2889	7-6-2017
2890-3	5-4-2022
2892	10-13-2017
2893	10-16-2017
2894	10-16-2017
2895	10-16-2017
2896	8-9-2017
2897-1	12-18-2018
2898-1	6-19-2019
2899-1	6-19-2019
2900-1	6-19-2019
2901	12-11-2017
2902	12-12-2017
2903-1	12-7-2020
2904	12-18-2017
2905	12-11-2017
2906	12-21-2017
2907	12-11-2017
2909-1	7-2-2019
2910	3-5-2018
2911	3-5-2018
2912	3-5-2018
2914	3-5-2018
2916	4-6-2018
2917	6-19-2019
2918	1-18-2018
2919-1	8-5-2022
2920	1-18-2018
2921	5-7-2018
2923	6-26-2018	...	1-1-2024	...
2924	9-30-2018
2926	9-19-2018
2927	8-1-2018
2928	9-19-2018
2929	8-1-2018
2930	8-24-2018
2931	8-24-2018
2932	9-17-2018
2933	10-2-2018
2934	10-2-2018
2936	9-30-2018
2937	12-7-2018
2938-1	12-7-2020
2939	12-17-2018
2941	12-17-2018
2942	12-18-2018
2943	12-30-2018
2946-1	6-8-2020

Case	Approval Date	Errata	Impending Annulment Date	Annulled Date/ Supersedes
2947	1-7-2019
2949-1	9-14-2020
2951	3-13-2019
2953	5-16-2019
2956	3-13-2019
2957	4-12-2019
2958	7-2-2019
2959-1	6-24-2021
2960	6-19-2019
2961	6-19-2019
2962	7-18-2019	...	1-1-2024	...
2963	7-30-2019
2964	7-2-2019
2965	7-24-2019
2967	8-28-2019
2968	8-28-2019
2969-2	9-3-2020
2970	10-15-2018
2971-1	9-3-2020
2972	10-6-2019
2973	11-21-2019
2974	11-1-2019
2975	11-1-2019
2976	10-11-2021
2978	7-16-2020
2979	12-4-2019
2981	12-2-2019
2982-1	6-29-2022
2983	12-2-2019
2984-1	2-8-2022
2985	12-2-2019
2986-1	7-24-2020
2987	1-21-2020
2988	1-21-2020
2989	1-21-2020
2990	3-13-2020
2991	3-13-2020
2993	3-13-2020
2995	4-2-2020
2996-1	7-15-2020
2998-1	9-15-2020
3000	6-4-2020
3001	4-23-2020
3002	7-9-2020
3003	7-15-2020
3004	7-15-2020
3005	9-3-2020	...	1-1-2024	...
3006	9-3-2020
3007	9-8-2020
3008	9-15-2020
3010	10-6-2020
3012	12-9-2020
3013	1-4-2021	3-30-2023
3014	12-10-2020
3015	1-20-2021	6-21-2023
3016	1-28-2021
3017	2-23-2021
3018	3-16-2021
3020	5-24-2021
3021	4-12-2021
3022	6-24-2021

Case	Approval Date	Errata	Impending Annulment Date	Annulled Date/Supersedes
3023	6-24-2021
3024	7-22-2021
3025	6-24-2021
3026	7-15-2021
3027	8-9-2021
3028	7-15-2021
3029	6-24-2021
3030	8-19-2021
3031	8-20-2021
3032	9-2-2021
3033	11-27-2021
3034	12-15-2021
3035	1-3-2022
3036	1-6-2022
3037	2-7-2022
3038	1-10-2022
3039	3-3-2022
3040	3-17-2022
3041	4-1-2022
3042	4-1-2022
3043	4-1-2022
3044	4-6-2022
3045	4-6-2022
3046	4-26-2022
3047	6-4-2022
3048	5-4-2022
3049	5-4-2022
3050	7-12-2022
3051	8-22-2022
3052	8-29-2022
3053	8-30-2022
3054	9-6-2022
3055	8-5-2022
3056	9-6-2022
3057	9-16-2022
3058	9-6-2022
3059	9-6-2022
3060	9-2-2022
3061	10-17-2022
3062	11-29-2022
3063	12-7-2022
3064	12-21-2022
3065	1-2-2023
3066	12-7-2022
3067	12-12-2022
3068	12-7-2022
3069	1-23-2023
3070	2-7-2023

INTENTIONALLY LEFT BLANK

SUBJECT INDEX

Subject	Case
Section I	
Power Boilers	
2.25Cr-1.6W-V-Cb Material	2199
2.5Cr-1Mo-V-B-Ti Material	2540
9Cr-1Mo-V Material	2864
9Cr-1Mo-1W-Cb Material	2327
9Cr-1Mo-V Material, UNS J84090	2192
9Cr-2W, UNS K92460 Material	2179
9Cr-3W-3Co-Nd-B Material	2839
12Cr-2W-2Co-B Material	3001
12Cr-1.5W-1.6Co-B Material	2781
18Cr-11Ni-3Cu-Mo-Nb-B-N Austenitic Stainless Steel, UNS S34752	2984
18Cr-9Ni-2.5W-V-Cb Austenitic Seamless Tube Steel	2475
18Cr-10Ni-3Cu-Ti-Cb Seamless Austenitic Stainless Steel Tube ..	2512
20Cr-25Ni-1.5Mo-Cb-N Seamless Austenitic Stainless Steel Tube	2581
22Cr-15Ni-Cb-N Austenitic Stainless Steel Seamless Tubing	2598
22Cr-25Ni-3.5W-3Cu Austenitic Stainless Steel UNS S31035 ...	2753
25Cr-14Ni-Mo-Low C (UNS S30925) Seamless Austenitic Steel Tube	2639
47Ni-23Cr-23Fe-7W, UNS N06674, Alloy Seamless Pipe and Tube, and Forgings	2684
52Ni-22Cr-13Co-9Mo (UNS N06617) Welded Tube	2923
57Ni-22Cr-14W-2Mo-La Alloy (UNS N06230)	2665
57Ni-22Cr-14W-2Mo-La Alloy (UNS N06230) Autogenously Welded Tube and Seamless Pipe and Tube	2756
57Ni-22Cr-14W-2Mo-La Alloy (UNS N06230) Wrought and Welded Tubing	2792
57Ni-22Cr-14W-2Mo-La Alloy (UNS N06230), Subpart 3, Fig. NFN-24 Up to 1,800°F (982°C)	2671
58Ni-29Cr-9Fe Alloy (UNS N06690)	2809
Alloy UNS S30815 Up to 1,700°F (927°C)	2786
Alternate Rules to PG-26 for Nickel Base Alloys	2805
Alternate WPS Qualification	3021
Alternative Method for Protection Against Overpressure	3031
Alternative Methods for Stamping	2896
Alternative Rules for Access in Firetube Boilers	2841
Alternative Rules for Heat Treatment of Boiler External Piping.	1934
Alternative Welding Operator Performance Weld Qualification Test	2757
Application of the ASME Certification Mark	2710
ASTM A351/A351M-14 Grade HG10MnN (UNS J92604)	3049
ASTM A1091/A1091M-16, Grade C91 Castings	2917
ASTM B444-04 UNS N06852, 50Ni-21.5Cr-17.5Fe-9Mo-Nb, Solution Annealed Seamless Pipes and Tubes	2520
Austenitic Fe-27Ni-22Cr-7Mo-Mn-Cu-N Alloy (UNS S31277) ...	2458
Austenitic Fe-35Ni-27Cr Alloy (UNS S35045)	2304
Capacitor Discharge Welding of Thermocouples to Material Less Than 0.20 in. (5 mm) Minimum Wall Thickness	2986
Changeover Valves Installed Between Safety Valves or Safety Relief Valves and Boilers	2254
Corrosion-Resistant Cu-Sb Carbon Steel Tube and Seamless Pipe	2494
Cu-13Zn-1.1Ni-Si-Al Alloy Seamless Pipe and Tubing	2782
Design of Safety Valve Connections	1876

Subject	Case
Section I	
Power Boilers (Cont'd)	
Design Rules for Creep Strength Enhanced Ferritic (CSEF) Steels Which Are Creep Intolerant for Construction	3048
Exemption From Mandatory Requirement for Fusible Plug in Hand-Fired Boilers	2731
Exemption From Postweld Heat Treatment for SA-268 TP439 P-No. 7 Tube to SA-790 Alloy UNS S31803 P-No. 10H Header Welds	2666
Exemption from Preheat and PWHT for Autogenous Butt welding of SA-213/SA-213M T22 Seamless Tubing	2755
Extension of Joining Personnel's Qualification Continuity	2996
F-Number Grouping for 9Cr-1Mo-V FCAW Consumable	2297
F-Number Grouping for Co-26Cr-9Ni-5Mo-3Fe-2W Alloy (UNS R31233) Filler Metal	2969
F-Number Grouping for Cr-Fe-Ni-Mo-Cu, Classification UNS R20033 Filler Metal	2473
F-Number Grouping for Ni-Cr-Fe Filler Metals	2142
F-Number Grouping for Ni-Cr-Fe, Classification UNS W86152 and UNS W86056 Welding Electrodes	2143
F-Number Grouping for Ni-Fe-Cr, Classification UNS N08087 Welding Electrode	2734
F-Number Grouping for Ni-Fe-Cr, Classification UNS N08087 Welding Filler Metal	2733
Fe-10.5Cr-0.5Mo-V-Nb Material	2890
Fillet Welded Staybolts in Locomotive-Type Boilers Not Covered Under Part PL	3045
Forgings of Nickel-Iron-Chromium Alloys N08800 and N08810	1949
Grade 91 Steel, 9%Cr-1%Mo (UNS K90901)	2770
Gray Cast Iron Castings	1849
Instrumented Indentation Testing as Alternative Hardness Test for QW-290 Temper Bead Welding	2703
Low Power Density Laser Beam Welding	2827
Materials for Bodies, Bonnets, Yokes, Housings, and Holders of Pressure Relief Devices	1750
Method for Basing Design Values on Material Properties Affirmed by Material Manufacturers	2556
Ni-22Cr-14W-2Mo-La Alloy (UNS N06230)	2063
Ni-25Cr-9.5Fe-2.1Al Alloy (UNS N06025)	2359
Ni-25Cr-20Co Material, UNS N07740	2702
Ni-Cr-Co-Mo Alloy (UNS N06617)	2439
Ni-Cr-Co-Mo-Ti Precipitation Hardened Alloy UNS N07208	3024
Ni-Cr-Mo Alloy UNS N06022 for Code Construction for Temperatures up to 1250°F	2226
Ni-Fe-Cr Alloy N08801 for Water-Wetted Service	2357
Nickel-Chromium-Iron (Alloy N06600) for Water-Wetted Service	1827
Nickel-Chromium-Molybdenum-Columbium Alloy (UNS N06625)	1935
Nickel-Iron-Chromium Alloys 800 and 800H (UNS N08800 and N08810) and Nickel-Iron-Chromium-Molybdenum-Copper Low-Carbon Alloy (UNS N08028)	1325
Nickel-Iron-Chromium-Molybdenum-Copper Alloy (UNS N08825) for Water Wetted Service	1936

Subject	Case
Section I	
Power Boilers (Cont'd)	
Nickel-Molybdenum-Chromium Alloy (UNS N10276)	1924
Pilot-Operated Pressure Relief Valves for PG-67.2.6 Applications	2446
Postponement of Mandatory Date for Compliance	2640
Precipitation-Hardening Nickel Alloy (UNS N07718) Used as Bolting Material	1993
Preheat of Dissimilar Metal Welds	3044
Pressure Relief Valves That Exceed the Capability of Testing Laboratories	2397
PW-39.2.1, PWHT Requirements for P-No. 4 Material Welded to Lower P-Number Material	2741
PWHT Exemption When Using Laser Beam Welding to Attach Fins to P-No. 15E Pipe and Tube Materials	2927
Qualification of Partial-Penetration Groove Welds Using Laser or Electron Beam Welding	2868
Requirements for Use of an Alternative Test Method Under PG-73.4.2.2	2511
SA-487 Grade CA6NM Class A	2073
SB-407 UNS N06811, 42Ni-29Cr-28Fe-Mo-N, Seamless Pipes and Tubes	2518
Seamless 1.15Ni-0.65Cu-Mo-Cb Material	2353
Seamless 11Cr-2W Material	2180
Section VIII, Division 1 Plate-and-Frame Heat Exchanger in Section I Feedwater System	2817
Section VIII, Division 1, Unfired Steam Boiler in Section I System	1855
Sizing Pressure Relief Valves for Economizers	3067
Substitution of Base Metals for Weld Metal Overlay	2897
Table PW-39-1, Exemptions From Postweld Heat Treatment for P-No. 1 Group 1 Materials With CE Greater Than 0.45	2906
UNS N06696 Seamless Pipe, Tube, and Plate	2652
Unstayed Flat Head Constructed From Forged Material	2697
Use of A213/A213M-04 UNS S31060 Austenitic Stainless Steel Seamless Tubing and A240/A240M-04a ¹ UNS S31060 Austenitic Stainless Steel Plate	2430
Use of ASME B31.1, 2014 Edition	2851
Use of ASTM A106/A106M-08 as SA-106/SA-106M	2663
Use of ASTM A672-06 and A691-98(R2002) Electric-Fusion-Welded Pipe	2576
Use of ASTM A988/A988M-17 Hot Isostatically Pressure Consolidated Powder Metallurgy	2930
Use of ASTM A989/A989M-15 Hot Isostatically Pressure Consolidated Powder Flanges, Fittings, Valves, and Parts	2931
Use of ASTM B834-15, Pressure Consolidated Powder Metallurgy	2916
Use of B43 Seamless Red Brass Pipe (UNS C23000) With Drawn General Purpose Temper (H58) for Threaded Piping for Construction of PMB and PEB Miniature Electric Boilers	2172
Use of Backing in Helical Butt-Welded Joints Under External Pressure	2957
Use of Capacitive Discharge Welding for Joining Non-Load-Bearing Attachments to P-No. 15E Group No. 1 Materials	2649
Use of Carbon and Low Alloy Steel Plate, AS 1548-2008 Grades PT430N/PT430NR, PT460N/PT460NR, and PT490N/PT490NR	2645
Use of Eccentric Crossings in Construction	2995
Use of Glass Bull's-Eye Water Level Indicators on Electric Boilers	2715
Use of Magnetically Impelled Arc Butt Welding (MIABW)	2694
Use of Manual Ultrasonic Examination of Welds	3026
Use of Materials in a Current Code Edition for a Boiler Constructed to an Earlier Code Edition	2595
Use of Metric Units	2523

Subject	Case
Section I	
Power Boilers (Cont'd)	
Use of Mn- $\frac{1}{2}$ Mo- $\frac{1}{2}$ Ni (UNS K12039) Pipe	2440
Use of PRT I Designator	3028
Use of SA-36/SA-36M and SA-675/SA-675M, Rectangular Carbon Steel Bars for Stiffening Rings	2929
Use of SA-240/SA-240M UNS S41003 Plates in the Construction of Boilers	2696
Use of SA-268/SA-268M, UNS S43932 Seamless and Welded Tubes	3014
Use of SA-350, Grade LF2, Class 1 Steel Forgings	2606
Use of SA-420, Grade WPL6 and Welded Steel Fittings	2607
Use of SA-508 Class 1, Grades 2 and 3 Forgings	2489
Use of Ultrasonic Examination in Lieu of Radiography for Material Thickness Less Than $\frac{1}{2}$ in. (13 mm) But Greater Than or Equal to $\frac{1}{4}$ in. (6 mm)	2816
Use of UNS N06625 Nickel Alloy (60Ni-22Cr-9Mo-3.5Cb) Annealed Grade 1 in Welded Tube, Plate, Sheet, and Strip	2632
Use of UNS N08367 Material for Construction	2810
Use of UNS S31042 Austenitic Stainless Steel in the Form of ASTM A213/A213M-21b Seamless Tube in Construction	3061
Section II	
Materials Part A — Ferrous	
F-Number Grouping for 9Cr-1Mo-V FCAW Consumable	2297
F-Number Grouping for Ni-Cr-Fe, Classification UNS W86152 and UNS W86056 Welding Electrodes	2143
Section II	
Materials Part B — Nonferrous	
57Ni-22Cr-14W-2Mo-La Alloy (UNS N06230) Wrought and Welded Tubing	2792
F-Number Grouping for 9Cr-1Mo-V FCAW Consumable	2297
F-Number Grouping for Ni-Cr-Fe, Classification UNS W86152 and UNS W86056 Welding Electrodes	2143
Use of 5052-H32, 6061-T6, and 6061-T651 Temper Aluminum Alloys in Part HF of Section IV, for Construction of Heating Boilers	2432
Section II	
Welding Specifications — Part C	
F-Number Grouping for 9Cr-1Mo-V FCAW Consumable	2297
F-Number Grouping for Ni-Cr-Fe, Classification UNS W86152 and UNS W86056 Welding Electrodes	2143
Welding Filler Metals	2798
Section II	
Material Properties — Part D	
57Ni-22Cr-14W-2Mo-La Alloy (UNS N06230), Subpart 3, Fig. NFN-24 Up to 1,800°F (982°C)	2671
F-Number Grouping for 9Cr-1Mo-V FCAW Consumable	2297
F-Number Grouping for Ni-Cr-Fe, Classification UNS W86152 and UNS W86056 Welding Electrodes	2143
Section IV	
Heating Boilers	
Allowance to Use Provisions of HG-402.5 as Alternative to Using Steam to Determine Set Pressure for "Pressure Only" Safety Relief Valves During Capacity Certification Testing	2692
Allowing Burst Testing to Determine MAWP of HLW Water Heaters and Storage Tanks	2937
Allowing Nameplate to Be Placed in Alternate Location Due to Insufficient Space	2876
Allowing Nameplates With Thinner Nominal Thickness	2993
Allowing the Use of SB-543 Alloy UNS C70600 Tube	2768
Alloy SUS 430J1L/JIS G 4305:2005 Plates for Part HF	2763
Alloy SUS 430J1L/JIS G 4305:2005 Plates for Part HLW	2765

<u>Subject</u>	<u>Case</u>	<u>Subject</u>	<u>Case</u>
Section IV		Section IV	
Heating Boilers (Cont'd)		Heating Boilers (Cont'd)	
Alloy SUS 430J1LTB/JIS G 3463:2006 Tubes for Heating Boilers	2801	UNS S31635 Tubing	2687
Alloy SUS 430J1LTB/JIS G 3463:2006 Tubes for Water Heaters	2802	UNS S31635 Tubing for Construction of Water Heaters	2723
Alternate Brazing Requirements for Pressure and Nonpressure Parts	2886	Use of 5052-H32, 6061-T6, and 6061-T651 Temper Aluminum Alloys in Part HF of Section IV, for Construction of Heating Boilers	2432
Alternate Safety Relief Valve Mounting for Low Mass Watertube Boilers and Water Heaters	2887	Use of Alloy SUS304TB Tube in Accordance With JIS G 3463:2012 in the Construction of Heating Boilers Under Part HF	2989
Alternative Minimum Thickness Requirements for Part HLW Water Heaters and Storage Tanks	3025	Use of Alloy SUS304TP Pipe in Accordance With JIS G 3459:2016 in the Construction of Heating Boilers Per Part HF	2976
Alternative Rules for Access and Inspection of a Water Boiler 60 in. (1 500 mm) or Over in Diameter	3051	Use of Alloy SUS315J1TB Tube in Accordance With JIS G 3463:2012 in the Construction of Heating Boilers Per Part HF	2960
Alternative Rules for Design Temperature of Plain Furnaces	2963	Use of Alloy SUS315J1TP Pipe in Accordance With JIS G 3459:2016 in the Construction of Heating Boilers Per Part HF	2953
Alternative Rules for Drain Valve Requirements on Modular Hot Water Boilers, HG-716(a)(3)(-b)	2873	Use of Alloy SUS444TB Tubing in Accordance With JIS G 3463:2012 in the Construction of Heating Boilers Per Part HF	2933
Application of the ASME Certification Mark	2710	Use of Alloy SUS444TP Pipe in Accordance With JIS G 3459:2016 in the Construction of Heating Boilers Per Part HF	2934
Attaching Nozzles and Fittings to Headers and Vessels	2690	Use of Aluminum Alloy EN AW-6060 T1 Extruded (Integrally) Finned Tube in the Manufacture of Hot Water Heating Boilers	2627
Attaching Tubes to Tubesheets Using GTAW Welding	3062	Use of Aluminum Alloy EN AW-6060 T66 Extruded Tube in the Manufacture of Hot Water Heating Boilers	2978
Attaching Tubes to Tubesheets Using Laser Beam Welding Without Full Penetration	2760	Use of an Automatic Pressure Decay Test for Part HLW Water Heaters	3023
Automatic Pressure Decay Test in Lieu of Hydrostatic Testing	2826	Use of ASTM A106/A106M-08 as SA-106/SA-106M	2663
Burst Testing Per HG-502.3 in Lieu of Proof Testing Per HLW-500 to Determine MAWP of HLW Items	2850	Use of ASTM A576 Hot-Wrought Carbon Steel Bars for Forming Fittings for HLW Construction	2500
Combination Boilers	3010	Use of Austenitic Stainless Steel Material With Minimum Thickness of 0.020 in. (0.5 mm) for Hot Water Heating Boilers	2688
Copper Alloys	2570	Use of Austenitic Stainless Steel on HLW Water Heaters for Potable Water Applications	2656
Corner Weld With Partial Penetration for Construction of Stainless Steel Hot Water Heating Boiler	3004	Use of Austenitic Stainless Steel SA-312/SA-312M Type 316Ti (UNS S31635) in the Construction of Heating Boilers	2849
Depth of Bevel for Tubes Attached by Welding	2947	Use of EN 10025-2 Gr. S235JR Plate in the Construction of Boilers	2720
Drain Valve on Horizontal Helical Coil Watertube Boilers	2529	Use of EN 10088-2 Gr. X6CrNiMoTi 17-12-2 Sheet, Plate, and Strip in the Construction of Boilers	2719
Exemption from Minimum Required Thickness, HF-301.1	2885	Use of EN 10217-1 Gr. P235TR2 Tubes in the Construction of Boilers	2721
Extension of Joining Personnel's Qualification Continuity	2996	Use of ER310 Filler Metals to Weld UNS S43035, Grades 439 and TP439 Materials to Austenitic Grades 304, 304L, 316, 316L, and 316Ti for the Construction of Heating Boilers	2724
F-Number Grouping for 9Cr-1Mo-V FCAW Consumable	2297	Use of JIS G 4305:2012 Alloy SUS304L in the Construction of Heating Boilers Under Part HF	2900
F-Number Grouping for Ni-Cr-Fe, Classification UNS W86152 and UNS W86056 Welding Electrodes	2143	Use of JIS G 4305:2012 Alloy SUS315J1 in the Construction of Heating Boilers Under Part HF	2899
HG-701.1 Permissible Mounting Safety Relief Valves for Coil-Type Water Boilers	2568	Use of JIS G 4305:2012 Alloy SUS444 in the Construction of Heating Boilers Under Part HF	2898
HLW-401.4(a), Distortion in Lined Vessels	2904	Use of Materials from the 2019 Edition	3033
Joining of SB-283, UNS C37700 Fittings to SB-75 Tubing	2791	Use of Metric Units	2523
Laser Marking of Welded Hot Water Heating Boilers	2813	Use of Nickel Alloy UNS N08367 in Construction of Boilers	2693
Locating Drain Fitting in Location Other Than That Specified in HLW-810(a)	2852	Use of Nickel Alloy UNS N08367 in the Manufacture of Part HLW Water Heaters and Storage Tanks	2973
Mandatory Appendix 5, Alternative Pressure Relief Device	2968	Use of Pneumatic Testing on Individual Cast Aluminum Sections	2604
Marking by Laser Annealing of Part HLW Water Heaters and Storage Heaters	2902	Use of Polymer Material for Bolted Box Headers	2411
Marking for Small Parts 5 in. (125 mm) O.D. and Under	2972	Use of SA-240 Grade 904L (UNS N08904)	2546
Modular Hot Water Boiler Certified as a Single Boiler	2874	Use of SA-240 Types 316Ti, 316L, 439 (UNS S43035), and UNS S43932 to Construct Water Heating Boilers With Cylindrical Parts Larger Than 38 in. (950 mm) Outside Diameter	2769
Modular Hot Water Supply Boilers	2893		
Modular Potable Water Heaters	2882		
Mounting Safety and Safety Relief Valves for Coil Type Heating Boilers	2565		
Part Marking for Small Parts 5 in. (125 mm) O.D. and Under	2962		
Phenolic Lining Material in HLW-200 Application	2613		
Pneumatic Testing	2469		
Pneumatic Testing in Lieu of Hydrostatic Test	2883		
Pneumatic Testing of Welded Hot Water Heating Boilers	2812		
Polymer Material for Heating Boiler Components	2725		
Qualification of Partial and Full Penetration Corner Joints Using Laser Beam Welding	3003		
Resistance Welding for Fittings and Nozzles	2848		
Revised Manufacturer's Data Reports	2691		
SA/EN10028-2 Grades P235GH, P265GH, P295GH, and P355GH	2779		
Tubes Attached by Welding	2657		

Subject	Case
Section IV	
Heating Boilers (Cont'd)	
Use of SA-240, Grades 304L and 316L in Thickness Less Than 1/4 in. (6 mm)	2571
Use of SA-240/SA-240M Plate Material, UNS S31635, Grades 316Ti and 439, UNS S43932 and UNS S43940, With Minimum Thickness of 0.0394 in. (1.0 mm) After Forming	2946
Use of SA-240/SA-240M Types 304L, 316Ti, 316L, 439 (UNS S43035), and UNS S43932 to Construct Water Heating Boilers for a Maximum Pressure of 160 psi (1 100 kPa)	2764
Use of SA-240/SA-240M UNS S41003 Plate in the Construction of Boilers	2707
Use of SA-240/SA-240M UNS S43035 (Grade 439) and UNS S43932 Less Than 1/4 in. (6 mm) in Thickness for the Construction of Water Boilers Intended for Working Pressures Up to 160 psi (1 100 kPa) Under Part HF	2708
Use of SA-240/SA-240M, Alloys 439 and UNS S43932, and SA-268, alloy TP439 Up to 210°F (99°C) in Heating Boiler Construction	2722
Use of SA-240/SA-240M, Plate Alloy Steel, Grades 304L and 316L With Thickness Less Than 1/8 in. (3 mm)	2872
Use of SA-240/SA-240M, Types 316Ti, 316L, 439, and UNS S43932 With Thickness Less Than 3/32 in. (2.5 mm)	2871
Use of SA-268 Grades UNS S43932 and UNS S43940 Conforming to SA-268 in the Manufacture of Heating Boilers	2668
Use of Sand Cast Aluminum Alloy EN AC-43000, AlSi10Mg(a), F Temper	2773
Use of SB-148 C95500, As-Cast Temper, in the Manufacture of Heating Boilers, Part HF and Potable-Water Heaters, Part HLW	2618
Use of SB-241/SB-241M Grade 6063 T1 (UNS A96063) Aluminum Alloy Extruded (Integrally) Finned and Coiled Tube in the Manufacture of Hot Water Heating Boilers	2628
Use of SB-584 (UNS C87500) Copper Alloy Sand Castings in the Manufacture of Nonstandard Pressure Parts for Hot Water Heating Boilers and Potable Water Heaters	2706
Use of Silicone Rubber O-Rings for Installing Tubes in Hot Water Heating Boilers and Potable Water Heaters	2888
Use of Stainless Steel Material With a Minimum Thickness of 0.0157 in. (0.4 mm) for Hot Water Heating Boilers	2869
Use of Stainless Steel Plate and Tube for Hot Water Heating Boilers	2870
Use of Stud Welding for Fitting Attachment of Part HG Boilers Fabricated by Welding	2967
Use of Stud Welding for Fitting Attachment of Part HLW Water Heaters and Storage Heaters	2961
Use of Thermometers With Minimum Full-Scale Range of 50°F to 250°F (10°C to 120°C)	2803
Use of UNS C12200 ASTM B359/B359M-18 With O62 Temper in the Manufacture of Part HLW Water Heaters and Part HF Boilers	2987
Use of UNS C69300 Copper-Zinc-Silicon Alloy Rod in the Manufacture of Pressure Parts for Hot Water Heating Boilers and Potable-Water Heaters	2880
Use of UNS N08904 (904L) Austenitic Stainless Steel Plate, Sheet, Strip in the Manufacture of Part HLW Water Heaters and Storage Tanks	2875
Use of UNS N08926 Austenitic Stainless Steel Plate, Sheet, and Strip in the Welded Construction of Hot Water Heating Boilers and Hot Water Supply Boilers	3030
Use of UNS R50400 Titanium Seamless and Welded Tube	2824

Subject	Case
Section IV	
Heating Boilers (Cont'd)	
Use of UNS S31254 Austenitic Stainless Steel Plate, Sheet, Strip, and Tube in the Manufacture of Part HLW Water Heaters and Storage Tanks	2895
Use of UNS S31254 Austenitic Stainless Steel Plate, Sheet, Strip, and Tube in the Welded Construction of Hot Water Heating Boilers	2894
Use of UNS S31635 (316Ti) Austenitic Stainless Steel in SA-312/SA-312M Seamless and Welded Pipe in the Manufacture of Part HLW Water Heaters and Storage Tanks	2988
Use of UNS S32003 Ferritic/Austenitic Stainless Steel Plate, Pipe, and Tube	2643
Use of UNS S32003 Ferritic/Austenitic Stainless Steel Plate, Pipe, and Tube for Boilers	2823
Use of UNS S32101 Ferritic/Austenitic Stainless Steel Plate, Sheet, Strip, Pipe, and Tube	2603
Use of UNS S32101 Ferritic/Austenitic Stainless Steel Plate, Sheet, Strip, Pipe, and Tube in the Manufacture of Part HLW Water Heaters and Storage Tanks	2620
Use of UNS S32205 Ferritic/Austenitic Stainless Steel [™] Plate, Pipe, and Tube	2761
Use of UNS S32205 Ferritic/Austenitic Stainless Steel Plate, Sheet, Strip, Pipe, and Tube in the Manufacture of Part HLW Water Heaters and Storage Tanks	2778
Use of UNS S43932 Ferritic Stainless Steel in SA-240/SA-240M Plate, Sheet, Strip, and in SA-268/SA-268M Welded and Seamless Tube	3027
Use of UNS S82012 and S82031 Duplex Stainless Steel Plate, Sheet, and Strip	2861
Use of UNS S82012 and S82031 Duplex Stainless Steel Plate, Sheet, and Strip in the Manufacture of Part HLW Water Heaters and Storage Tanks	2860
Valve Markings	2256
Section VIII, Division 1	
Pressure Vessels	
7% Ni Thermo-Mechanical Control Processed Steel Plate for Cryogenic Applications	2736
9Cr-2Si-1Cu Material	3007
9Cr-2W, UNS K92460 Material	2179
18Cr-11Ni-3Cu-Mo-Nb-B-N Austenitic Stainless Steel, UNS S34752	2984
18Cr-13Ni-3.7Mo-Nb-N Austenitic Stainless Steel, UNS S31740	3038
18Cr-15Ni-4Mo-3Cu-N, UNS S31727, Austenitic Stainless Steel	2617
18.5Cr-15.5Ni-4.5Mo-N Alloy (UNS S31726) Austenitic Stainless Steel	2197
20Cr-8.5Ni-0.7Mo-0.2N, UNS S31655 Austenitic Steel, Alloy Plate, Sheet, and Strip, Welded Tubing, Seamless and Welded Pipe	2903
22Cr-25Ni-3.5W-3Cu Austenitic Stainless Steel UNS S31035	2752
23Cr-25Ni-5.5Mo-N, UNS S32053, Austenitic -Stainless Steel	2445
23Cr-35Ni-7.5Mo-N, UNS N08354, Austenitic Alloy	2585
24Cr-4Ni-3Mn-1.6Mo-0.27N, UNS S82441 Ferritic/Austenitic Steel, Alloy Plate, Sheet, and Strip; Bar; Seamless and Welded Tube; Seamless and Welded Pipe	2780
24Cr-17Ni-6Mn-4.5Mo-N, UNS S34565, Austenitic Stainless Steel Forgings, Bar, Fittings, Welded and Seamless Pipe and Tube, Plate, Sheet, and Strip	2146
24.5Cr-22Ni-7.5Mo-3Mn-N Austenitic Stainless Steel (UNS S32654)	2195
25Cr-7.5Ni-4.5Mo-Co-N Austenitic-Ferritic Stainless Steel UNS S32707	2586

Subject	Case	Subject	Case
Section VIII, Division 1 Pressure Vessels (Cont'd)		Section VIII, Division 1 Pressure Vessels (Cont'd)	
25Cr-20Ni Austenitic Stainless Steel UNS S31002	2591	Alternative Rules for Ellipsoidal or Torispherical Heads Having Integral Backing Strip Attached to Shells	2346
25Cr-22Ni-2Mo-N, UNS S31050, Austenitic Stainless Steel Forgings	2038	Alternative Rules for Hemispherical Head Attached to Cylindrical Shell Having Integral Backing Ring That Is Part of the Shell ..	2751
27Cr-7.6Ni-1Mo-2.3W-N UNS S32808, Solution Annealed Austenitic-Ferritic Duplex Stainless Steel Plate, Seamless Tubing, Seamless Pipe, Forgings, and Bar for Class 2	2496	Alternative Rules for the Design of U-Tube Tubesheets, Configurations a and e	2965
29Cr-6.5Ni-2Mo-N Austenitic-Ferritic Stainless Steel, UNS S32906 Hot Isostatically-Pressed Material (Class 2)	2840	Alternative Rules for the Postweld Heat Treatment of Finned Tubes	2400
30Cr-7Ni-3.5Mo-N, UNS S83071, Austenitic-Ferritic Stainless Steel	2914	Alternative Set Pressure Testing of Pilot-Operated Pressure Relief Valves	3057
35Ni-30Fe-27Cr-6.5Mo-N Nickel Alloy, UNS N08935	2982	Alternative Welding Operator Performance Weld Qualification Test	2757
37Ni-30Co-28Cr-2.75Si Alloy (UNS N12160)	2385	Aluminum Alloy (Aluminum-6.3Magnesium) for Code Construction	2403
37Ni-33Fe-25Cr Alloy (UNS N08120) Welded Construction Above 1650°F to 1800°F	2672	Annealed Copper SB-152, UNS C10100, O25 Temper	2859
47Ni-23Cr-23Fe-7W, UNS N06674, Alloy Seamless Pipe and Tube, and Forgings	2684	Applicability of ASTM B432 for Construction of Pressure Vessels ASTM A240/A240M-09a UNS S30530 Solution Annealed	2928
52Ni-22Cr-13Co-9Mo (UNS N06617) Welded Tube	2923	Austenitic Stainless Steel Plate and Sheet	2636
57Ni-22Cr-14W-2Mo-La Alloy (UNS N06230) Wrought and Welded Tubing	2792	ASTM B16 Material in Pressure Boundary of Vessel	2881
57Ni-22Cr-14W-2Mo-La Alloy (UNS N06230), Subpart 3, Fig. NFN-24 Up to 1,800°F (982°C)	2671	Attachment of Tubes to Flat Tubesheets Using Complete Penetration Welds	2428
2014-T6 Aluminum Hand Forgings for Nonwelded Construction	2616	Austenitic Fe-27Ni-22Cr-7Mo-Mn-Cu-N Alloy (UNS S31277) ..	2458
A439 Type D-2 Austenitic Ductile Iron	2093	Austenitic Fe-35Ni-27Cr Alloy (UNS S35045)	2304
Allowable Compressive Stress in the Time-Dependent Regime	2964	Austenitic Ni-Cr-Mo-Nb Alloy (UNS N06626)	2276
Alloy UNS N06690 Up To 1200°F (649°C)	2629	Austenitic Stainless Steel Seamless Tubes and Pipe, Seamless Wrought Fittings, Plate, Sheet, and Forgings, 18Cr-11Ni-Cb-N, UNS S34751, 347LN	2196
Alloy UNS S30815 Up to 1,700°F (927°C)	2786	Cast ASTM B752-06 Zirconium Alloy Grades 702C and 705C ..	2633
Alternate NDE Method for Welded Spin Holes	2889	Cast Titanium Aluminum Vanadium Iron Alloy, SB-367, Grade C-38 (Ti 4Al-2.5V-1.5Fe) UNS R54250	2717
Alternate Rules for Heat Treatment of Repair Welds to Castings	2205	Chromium-Nickel-Molybdenum-Nitrogen-Tungsten Duplex Stainless Steel UNS S39274 Plate	2427
Alternate Rules for Quick-Actuating Closures	2912	Cold-Stretching of Austenitic Stainless Steel Pressure Vessels ..	2596
Alternative Approach for Operating Conditions (Including Occasional Loads) in the Time-Dependent Regime	2951	Cu-13Zn-1.1Ni-Si-Al Alloy Seamless Tubing	2783
Alternative Flanged Joint Design for Nuclear Material Fluidized Bed Reactors	2318	Diffusion Welding of Microchannel Heat Exchangers	3018
Alternative Method of Vessel Markings	2911	Evaluation of External Loads on Welding Neck Flanges Covered by Section VIII, Division 1, UG-44(b), (i), and (j); or Section VIII, Division 2, 4.1.11.1(a) and (g), and 4.1.11.3	2901
Alternative Pore Evaluation and Acceptance Criteria for Diffusion Welded Material, Mandatory Appendix 42	3046	Exceptions to Requirements of Figure UW-13.2, Sketches (m) and (n)	2772
Alternative Pressure Test Procedure to UG-99 and UG-100 for the Construction of Multistream Aluminum Vacuum Brazed Plate-Fin Heat Exchangers	2247	Exemption From Post-Bending Heat Treatment Requirements for Carbon and Low-Alloy Steel Tube and Pipe	2807
Alternative Procedure for Calculating Allowable Axial Compressive Stress and External Pressure in Cylindrical Shells Constructed of Stainless Steel Alloy 253MA (UNS S30815) at Temperatures Greater Than 1200°F (650°C) and Less Than or Equal to 1650°F (900°C)	2682	Exemption From Postweld Heat Treatment for P-No. 4 or P-No. 5A Tube-to-Tubesheet Seal Welds	2321
Alternative Procedure for Calculating Allowable Axial Compressive Stress in Cylindrical Shells Constructed of 2 ¹ / ₄ Cr-1Mo Steel at Temperatures Greater Than 700°F and Less Than or Equal to 1000°F	2676	Exemption From Postweld NDE Requirements of UG-93(d)(4)-(b) on Fig. UW-13.2(d) Construction	2305
Alternative Requirements for Certifying Engineer Qualification	3036	Exemption from PWHT Requirements in Table UCS-56-3 for Seal Welds Between P-No. 4 Tubes and P-No. 4 Tubesheets	2858
Alternative Requirements for Seal Welding of Threaded Connections, UF-32(b)	2016	Exemption From Repeated Mechanical Testing as per UCS-85(c) and (i)	2941
Alternative Rules for Appendix 24 When Controlled Bolting Is Used	2658	Extending Mandatory Appendix 34 to Use PAW to Weld UNS S32615 Meeting the Requirements of SA-240/SA-240M	2985
Alternative Rules for Brazing Qualifications	2351	Extension of Cementing Technicians Qualification Continuity, Part UIG	3008
Alternative Rules for Design of Ellipsoidal and Torispherical Formed Heads	2260	Extension of Joining Personnel's Qualification Continuity	2996
Alternative Rules for Designing U-Shaped Bellows	2587	F-Number Grouping for 9Cr-1Mo-V FCAW Consumable	2297
Alternative Rules for Determining Allowable External Pressure and Compressive Stresses for Cylinders, Cones, Spheres, and Formed Heads	2286	F-Number Grouping for 63Ni-22Mo-15Cr Alloy (UNS N10362) Filler Metal	2653
		F-Number Grouping for Co-26Cr-9Ni-5Mo-3Fe-2W Alloy (UNS R31233) Filler Metal	2969

Subject	Case
Section VIII, Division 1 Pressure Vessels (Cont'd)	
F-Number Grouping for Cr-Fe-Ni-Mo-Cu, Classification UNS R20033 Filler Metal	2473
F-Number Grouping for Ni-Cr-Fe Filler Metals	2142
F-Number Grouping for Ni-Cr-Fe, Classification UNS W86152 and UNS W86056 Welding Electrodes	2143
F-Number Grouping for Ni-Fe-Cr, Classification UNS N08087 Welding Electrode	2734
F-Number Grouping for Ni-Fe-Cr, Classification UNS N08087 Welding Filler Metal	2733
Figure UW-13.4, Illustration (a)	2814
Full-Strength and Partial-Strength Inset Tube-to-Tubesheet Welds	2942
Heat-Affected Zone Impact Testing in Weld Procedure Qualification, UG-84(g)(2)	2835
Hydrostatic and Pneumatic Testing of Mass-Produced Pressure Vessels With an Intermediate Isolation Valve Between Indicating Gage and Pressure Vessel	2726
Impact Test Requirements of Part UHA Materials Joined by Diffusion Welding	3054
Implementation of Changes in Division 1, 31-4 (a) and (b) and Division 2, 3.4.4.1 and 3.4.4.2	2844
Induction Kinetic Welding	2799
Inspection Openings in Small Pressure Vessels	2634
Large-End Cone-to-Cylinder Junction for $30 < \alpha \leq 60$ Degrees ..	2150
Laser Annealing of Nameplates	2959
Laser Measurement for Out-of-Roundness	2789
Low Power Density Laser Beam Welding	2827
Mandatory Appendix 26, Fatigue Design Curve for Other Materials for Expansion Joints	3013
Manufacturer's Data Reports	2738
Material of Minor Attachments Welded Directly to Pressure Parts Made of Q&T Steels Covered by Table UHT-23 of Division 1 and Table 3-A.2 of Division 2	2865
Materials for Bodies, Bonnets, Yokes, Housings, and Holders of Pressure Relief Devices	1750
Method for Basing Design Values on Material Properties Affirmed by Material Manufacturers	2556
Minimum Thickness of Furnace Brazed Plate Heat Exchanger Heads	2538
Minimum Thickness of Standard Fittings Under UW-16(f)(3)(-a)(-6)	3035
Multiple Marking of Certified Capacities for Pressure-Relief Valves	2787
Ni-25Cr-9.5Fe-2.1Al Alloy (UNS N06025)	2359
Ni-25Cr-20Co Material, UNS N07740	3056
Ni-29Cr-3.5Fe-3.3Al-1.5Nb Alloy (UNS N06693)	2481
Ni-Cr-Co-Mo-Ti Precipitation Hardened Alloy UNS N07208	3024
Ni-Cr-Mo Bolting Material UNS N06059, ASTM F468-06	2588
Ni-Cr-Mo-Cu Alloy UNS N06235	3058
Nickel-Iron-Chromium-Molybdenum-Copper Low Carbon Alloy (UNS N08926) for Code Construction	2120
Omission of Lifting Device Requirements for Pressure Relief Valves on Air, Water Over 140°F (60°C), or Steam Service ...	2203
Parallel Plate Explosion Welding for Butt Joints Between Dissimilar Metals	2493
Pneumatic Test	2407
Pneumatic Testing of Pressure Vessels, U-1(j), UM Vessels	2527
Pneumatic Testing of Pressure Vessels, UG-20	2055
Precipitation-Hardening Ni-Cr-Mo Alloy (UNS N07725)	2217

Subject	Case
Section VIII, Division 1 Pressure Vessels (Cont'd)	
Precipitation-Hardening Nickel Alloy (UNS N07718) Used as Pressure Retaining Component Material	2222
Qualification of Partial-Penetration Groove Welds Using Laser or Electron Beam Welding	2868
Qualification of Welding Procedures for High Frequency Induction Longitudinal Butt Welds in Tube Construction	2971
Radiographic Requirements for SA-612 Steel Plate	2377
Removal of Nameplate With Certification Mark from Prefabricated or Preformed Parts	2825
SA-182, SA-240, SA-479, SA-789, SA-790, and SA-815 21Cr-5Mn-1.5Ni-Cu-N (UNS S32101) Austenitic-Ferritic Duplex Stainless Steel	2418
SA-240/SA-240M, UNS S43035 Plate	2758
SA-240/SA-240M, UNS S43932 Plate	2788
SA-453, Grade 660, Class C, High Temperature Bolting Materials With Expansion Coefficients Comparable to Austenitic Steels	2610
SA-736/SA-736M Plates and ASTM A859/A859M-95 Forgings .	1932
SA-995, UNS J92205, (CD3MN), Austenitic/Ferritic Duplex Stainless Steel	2402
SA/EN 10025-2 Steel Grades S235J2, S275J2, and S355J2	2811
SB-407 UNS N06811, 42Ni-29Cr-28Fe-Mo-N, Seamless Pipes and Tubes	2518
Single Fillet Lap Joint for Heat Exchanger Tube Welds	2421
Single Fillet Lap Joints in the Shell of a Shell-and-Tube Heat Exchanger	2334
Solution Annealed Ni-Cr-Mo UNS N06058 Alloy Wrought Fittings, Forgings, Bar, Plate, Sheet, Strip, Welded Pipe, Seamless Pipe and Tube, and Welded Tube for Class 1	2983
Solution Annealed Ni-Fe-Cr-Mo-Cu Low Carbon Alloy (UNS N08034) Wrought Fittings, Forgings, Bar, Plate, Sheet, Strip, Welded Pipe, Seamless Pipe and Tube, and Welded Tube for Class 1	2991
Solution Annealed Ni-24Fe-23Cr-6Mo-3Cu, UNS N06845, Seamless Pipe and Tube, Plate, Sheet, Strip, Rod, and Bar ...	2794
Solution Annealed Ni-44Cr-1Mo (UNS N06044) for Plate-Sheet-Strip, Seamless and Welded Fittings, Seamless Pipe and Tube, Forgings, Welded Pipe, Welded Tube and Rod	3006
Spherical Intermediate Head or End Closure Without Straight Flange	2712
Strength of Aluminum Brazed Joints Up to 400°F	2350
Supply of Dimpled or Embossed Panels in the Unpillowed Condition	2909
Tack Welds on Heat Transfer Plates Left In-Place Without Qualification, UW-31(c)	3000
Testing of Vessels Containing an Internal Piston	2608
Thermo-Mechanical Control Processed 7% Ni Steel Plate	2750
Titanium Aluminum Alloy, ASTM B367-08b, Ti 3Al-2.5V or Ti 3Al-2.5V-0.05Pd Castings	2631
Titanium Nickel Molybdenum Alloy (Ti 0.8Ni-0.3Mo), Grade C-12 Castings	2641
Titanium Nickel-Molybdenum Ruthenium Alloy, Ti-0.8Ni-0.3Mo-0.1Ru	2426
Tolerance for Formed Heads for External Pressure Design Conditions	2544
Type 304LN (Alloy UNS S30453) Austenitic Stainless Steel	2127
UNS J93380 (CD3MWCuN)	2244
UNS N06696 Seamless Pipe, Tube, and Plate	2652
UNS S31266, 24Cr-22Ni-6Mo-2W-Cu-N Super Austenitic Stainless Steel (Class 2)	2831
Use of 1Cr- $\frac{1}{2}$ Mo Seamless Pipe for Pressure Purposes	2926

Subject	Case
Section VIII, Division 1 Pressure Vessels (Cont'd)	
Use of 1.15Ni-0.65Cu-Mo-Cb (UNS K21001) High-Strength Low-Alloy Steel Seamless Pipes and Tubes, Flat Products, Forgings, and Fittings	3037
Use of 17Cr-4Ni-4Cu (UNS S17400) Condition H1150D or H1150M	2784
Use of 52Ni-22Cr-13Co-9Mo (UNS N06617), Annealed Bolting Materials for Pressure Vessels	2776
Use of 57Ni-22Cr-14W-2Mo-La (UNS N06230), Solution-Annealed Bolting Materials for Pressure Vessels ...	2775
Use of 304L Stainless Steel at Elevated Temperatures	2224
Use of 316L Stainless Steel at Elevated Temperatures	2577
Use of A213/A213M-04 UNS S31060 Austenitic Stainless Steel Seamless Tubing and A240/A240M-04a ^{e1} UNS S31060 Austenitic Stainless Steel Plate	2430
Use of Acoustic Emission Examination in Lieu of Radiography .	1968
Use of Alternative Category B Weld Design	3068
Use of Appendix 23 for External Pressure Design of Copper and Copper Alloy Condenser and Heat Exchanger Tubes With Integral Fins at Elevated Temperatures	2686
Use of ASME B16.47-2020 in Lieu of ASME B16.47-2017	3043
Use of ASME B16.5-2020 in Lieu of ASME B16.5-2017	3042
Use of ASME B31.3, Appendix L Aluminum Pipe Flanges	2905
Use of ASTM A106/A106M-08 as SA-106/SA-106M	2663
Use of ASTM A234/A234M Butt Weld Elbows, Grade WPB	2830
Use of ASTM A312/A312M-16a Through 18a in Welded Construction in Lieu of SA-312/SA-312M for Grades TP316, TP316H, TP316N, and TP316LN	3015
Use of ASTM A372/A372M-16, Grade N, Classes 100 and 120 and Grade P, Classes 100 and 120	2892
Use of ASTM A414/A414M-07	2619
Use of Automated Ultrasound Leak Detection System in Lieu of Visual Inspections Required by UG-100(d)	2324
Use of Carbon and Low Alloy Steel Plate, AS 1548-2008 Grades PT430N/PT430NR, PT460N/PT460NR, and PT490N/PT490NR	2645
Use of Carbon Steel Pipe Without Requiring Bend or Pressure Testing	3047
Use of Compound Material to Produce Tubes, Part UIG	3041
Use of EN 10216-3:2013, Grade P460NL1, Fine-Grain Seamless Steel Tubes	2990
Use of EN 10216-3:2013, Grade P690QL2, Fine-Grain Seamless Steel Tubes; and EN 10028-6:2017, Grade P690QL2 Fine-Grain Flat Products	3052
Use of Existing Nameplates in Inventory for Construction	2979
Use of Furnace Brazing for Lethal Service	2249
Use of Hot-Isostatically Pressed Pure Isotropic Molybdenum ...	3063
Use of Material Test Report Mechanical Properties to Calculate the MAWP of Vessel or Component by Proof Testing in Accordance With UG-101(m)(2)	3065
Use of Ni-Al Bronze C95820 Sand Castings for Pressure Vessels	2230
Use of Noncode Pressure Relief Valves	2675
Use of Permanent Mold Cast Aluminum Alloys UNS A13560 and A03570	2239
Use of PFA Tubing Material for Flue Gas Heat Exchanger Tubes	2837
Use of PTFE Tubing Material for Flue Gas Heat Exchanger Tubes	2795
Use of Resistance Longitudinal Butt Welds for Cylinders	2777
Use of SA-193/SA-193M Grade B16 Bolting in Diameters Larger Than 7 in. (175 mm)	2754
Use of SA-268 Ferritic Stainless Steel Welded Tubing, TP430 Ti, UNS S43036	2419

Subject	Case
Section VIII, Division 1 Pressure Vessels (Cont'd)	
Use of SA-372 Grade E Class 55, Grade J Class 55, and Grade F, G, and H Class 55 and 65 Forgings, Quenched and Tempered ..	2300
Use of SA-705 Type 630 Forgings (UNS S17400) and SA-693 Type 630 Plate (UNS S17400)	2223
Use of SA/EN 10028-2, Grades P235GH and P265GH Steel	2498
Use of SA/IS 2062, Grades E250A, E250BR, E250B0, and E250C, Hot-Rolled Medium- and High-Tensile Strength Structural Steel Plates	3066
Use of SB-209 Alloys 5083, 5052, and 6061 Aluminum Flat Plates in Accordance with UG-93(d)(3) and (d)(4) for the Production of Heat Exchanger Components	3005
Use of SB-584 UNS C87500 Castings	3012
Use of Sintered Silicon Carbide (S-SiC) for Pressure Boundary Parts for Frame-and-Plate-Type Pressure Vessels	2867
Use of Types 308LSi and 316LSi Weld Filler Metals at MDMT Colder Than -320°F (-196°C)	3064
Use of UNS S82011 Stainless Steel	2735
Use of Welded UNS N02200, N02201, and N04400 Alloy Pipe and Tube	2767
Vessel (Production) Impact Tests for Welded Construction of Austenitic Stainless Steels	2704
Waiver of Production Impact Testing For Category B Welded Joints	3022
Waiver of UW-9(h)(4) Rules	3034
Waiver of Weld Joint Examination for Pneumatically Tested Braze Plate-Type Heat Exchangers That Have Been Previously Hydrostatically Tested	2774
Welded Austenitic Stainless Steel Condenser and Heat Exchanger Tubes With Textured Surfaces	2877
Welding of Aluminum Alloy Tube-to-Tubesheet Joints by Friction Stir Welding (FSW) Process	2677
Welding of Tubes to Tubesheets by Deformation Resistance Welding (DRW) Process	2463
Section VIII, Division 2 Pressure Vessels (Alternative Rules)	
3 Chromium-1 Molybdenum- ¹ / ₄ Vanadium-Columbium-Calcium Alloy Steel Plates and Forgings for Class 2	2151
7% Ni Thermo-Mechanical Control Processed Steel Plate for Cryogenic Applications for Class 2	2737
22Cr-5Ni-3Mo-N (UNS S31803) Use to 600°F (316°C) for Class 2	2727
25Cr-7Ni-4Mo-N (UNS S32750) Austenitic-Ferritic Stainless Steel for Class 2	2740
25Cr-22Ni-2Mo-N, UNS S31050, Austenitic Stainless Steel Forgings	2038
27Cr-7.6Ni-1Mo-2.3W-N UNS S32808, Solution Annealed Austenitic-Ferritic Duplex Stainless Steel Plate, Seamless Tubing, Seamless Pipe, Forgings, and Bar for Class 2	2496
29Cr-6.5Ni-2Mo-N Austenitic-Ferritic Stainless Steel, UNS S32906 Hot Isostatically-Pressed Material (Class 2)	2840
30Cr-7Ni-3.5Mo-N, UNS S83071, Austenitic-Ferritic Stainless Steel	2914
35Ni-30Fe-27Cr-6.5Mo-N Nickel Alloy, UNS N08935	2982
Allowable Compressive Stress in the Time-Dependent Regime .	3029
Allowable Stresses and Design Stress Intensities for Bolting Materials Listed in Both Tables 3 and 4 of Section II, Part D .	2730
Alternative Diameter-To-Thickness Ratios for Spherical and Formed Heads With Openings	2739
Alternative Flaw Evaluation and Acceptance Criteria for Subsurface Flaw Near Component Surface for Class 1 and Class 2	2958

Subject	Case
Section VIII, Division 2	
Pressure Vessels (Alternative Rules) (Cont'd)	
Alternative Minimum Test Temperature for Hydrostatic Testing	2718
Alternative Requirements for Certifying Engineer Qualification	3036
Alternative Rules for Para. 4.17 When Controlled Bolting Is Used	2659
Alternative Rules for the Design of U-Tube Tubesheets, Configurations a and e	2965
Alternative Set Pressure Testing of Pilot-Operated Pressure Relief Valves	3057
Alternative Welding Operator Performance Weld Qualification Test	2757
Analysis of Class 2 Components in the Time-Dependent Regime	2843
Composite Pressure Vessel Consisting of Inner Steel Layered Shell and Outer Reinforced and Prestressed Concrete Shell for Hydrogen Service for Class 2	2949
Corrected Forming Strain Equation, Table 6.1	2804
Design of Components in the Time-Dependent Regime Using Isochronous Stress-Strain Method for Class 2 Components	3060
Design of Hubless Integral Flanges Using Part 4.16	2833
Elevated Temperature Design of Bolting	2655
Evaluation of External Loads on Welding Neck Flanges Covered by Section VIII, Division 1, UG-44(b), (i), and (j); or Section VIII, Division 2, 4.1.11.1(a) and (g), and 4.1.11.3	2901
Extension of Joining Personnel's Qualification Continuity	2996
F-Number Grouping for 9Cr-1Mo-V FCAW Consumable	2297
F-Number Grouping for 63Ni-22Mo-15Cr Alloy (UNS N10362) Filler Metal	2653
F-Number Grouping for Cr-Fe-Ni-Mo-Cu, Classification UNS R20033 Filler Metal	2473
F-Number Grouping for Ni-Cr-Fe Filler Metals	2142
F-Number Grouping for Ni-Cr-Fe, Classification UNS W86152 and UNS W86056 Welding Electrodes	2143
F-Number Grouping for Ni-Fe-Cr, Classification UNS N08087 Welding Electrode	2734
F-Number Grouping for Ni-Fe-Cr, Classification UNS N08087 Welding Filler Metal	2733
Fatigue Evaluation for Class 2 Parts Constructed With SA-182 F22V; SA-336 F22V; SA-541 22V; SA-542 Type D, Class 4a; and SA-832 Grade 22V at Temperatures Greater Than 371°C (700°F) and Less Than or Equal to 482°C (900°F)	2605
Fatigue Evaluation for Class 2 Parts Constructed With SA-182/ SA-182M F91, SA-213/SA-213M T91, SA-335/SA-335M P91, SA-336/SA-336M F91, and SA-387/SA-387M 91 Class 2 at Temperatures Greater Than 371°C (700°F) and Less Than or Equal to 500°C (932°F)	2822
Full-Strength and Partial-Strength Inset Tube-to-Tubesheet Welds	2942
Heat-Affected Zone Impact Testing in Weld Procedure Qualification, Para. 3.11.8.2(c)	2924
Hillside Nozzle in Spherical Shell or Hemispherical Head in 4.5.11	2834
Impact Testing of SA-540/SA-540M, Grade B23, Class 3 Bolting	2821
Implementation of Changes in Division 1, 31-4 (a) and (b) and Division 2, 3.4.4.1 and 3.4.4.2	2844
Implementing in Parts 4 and 5 the Changes in ASCE/SEI 7-10, Paras. 2.3.2 and 2.4.1 for Wind Load Factors	2679
Induction Kinetic Welding	2799
Intermodal Transport Tanks (UN T50 Portable Tanks) for Class 2	2624
Laser Measurement for Out-of-Roundness	2789
Low Power Density Laser Beam Welding	2827
Manufacturer's Data Reports	2738

Subject	Case
Section VIII, Division 2	
Pressure Vessels (Alternative Rules) (Cont'd)	
Material of Minor Attachments Welded Directly to Pressure Parts Made of Q&T Steels Covered by Table UHT-23 of Division 1 and Table 3-A.2 of Division 2	2865
Method for Basing Design Values on Material Properties Affirmed by Material Manufacturers	2556
Omission of Lifting Device Requirements for Pressure Relief Valves on Air, Water Over 140°F (60°C), or Steam Service	2203
Other Recognized Standards for Definition of Wind and Earthquake Loading in Lieu of ASCE/SEI 7	2680
Parallel Plate Explosion Welding for Butt Joints Between Dissimilar Metals	2493
Precipitation-Hardening Ni-Cr-Mo Alloy (UNS N07725)	2217
Precipitation-Hardening Nickel Alloy (UNS N07718) Used as Pressure Retaining Component Material	2222
Qualification of Partial-Penetration Groove Welds Using Laser or Electron Beam Welding	2868
Rules for Calculating Maximum Permissible Gaps for Layered Vessels in 4.13.12.3	2806
SA-453, Grade 660, Class C, High Temperature Bolting Materials With Expansion Coefficients Comparable to Austenitic Steels	2610
SA-487/SA-487M Grade CA6NM Class A	2998
SA-736/SA-736M Plates and ASTM A859/A859M-95 Forgings	1932
Solution Annealed Ni-Cr-Mo UNS N06058 Alloy Wrought Fittings, Forgings, Bar, Plate, Sheet, Strip, Welded Pipe, Seamless Pipe and Tube, and Welded Tube for Class 1	2983
Solution Annealed Ni-Fe-Cr-Mo-Cu Low Carbon Alloy (UNS N08034) Wrought Fittings, Forgings, Bar, Plate, Sheet, Strip, Welded Pipe, Seamless Pipe and Tube, and Welded Tube for Class 1	2991
Spherical Intermediate Head or End Closure Without Straight Flange	2712
Time-Dependent Allowable Stresses for Class 1 Vessel Materials Listed in Table 2A or Table 2B of Section II, Part D	2943
Tolerance for External Pressure Design Conditions	2673
Unalloyed and Palladium or Ruthenium Enhanced Titanium H Grades With 400 MPa (58 ksi) Minimum UTS, UNS R50400, UNS R52400, UNS R52402, and UNS R52404	3059
UNS S31254 and UNS N08904 Austenitic Stainless Steel Plate, Sheet, and Strip	2808
UNS S31266, 24Cr-22Ni-6Mo-2W-Cu-N Super Austenitic Stainless Steel (Class 2)	2831
Use of 9Ni, 8Ni, and 5Ni- $\frac{1}{4}$ Mo Materials in Welded Condition for Class 2 Construction	2681
Use of 15Cr-5Ni-3Cu (UNS S15500)	2416
Use of AS 1548-2008 Grades PT430N/PT430NR, PT460N/ PT460NR, PT490N/PT490NR for Class 2	2711
Use of ASME B16.47-2020 in Lieu of ASME B16.47-2017	3043
Use of ASME B16.5-2020 in Lieu of ASME B16.5-2017	3042
Use of ASTM A106/A106M-08 as SA-106/SA-106M	2663
Use of ASTM A372/A372M-16, Grade N, Classes 100 and 120 and Grade P, Classes 100 and 120 for Class 2 Vessels	2939
Use of EN 10216-3:2013, Grade P690QL2, Fine-Grain Seamless Steel Tubes; and EN 10028-6:2017, Grade P690QL2 Fine-Grain Flat Products	3052
Use of EN 10222-2:1999, Grade 18MnMoNi5-5, Steel Forgings for Class 2	2749
Use of Fatigue Analysis Screening, Method A For Vessels Made of 1.25Cr-0.5Mo-Si and 2.25Cr-1Mo Steels	2630
Use of Hot-Isostatically Pressed Pure Isotropic Molybdenum	3063